

दूरभाष Phone : 91-481-2353311 to 20 (10 लाइनें Lines)
फैक्स Fax : 91-481-2353121 / 2353324

ई-मेल E-mail: qc@rubberboard.org.in
वेब साइट Website: www.rubberboard.org.in



रबर बोर्ड RUBBER BOARD

(वाणिज्य एवं उद्योग मंत्रालय, भारत सरकार)

(Ministry of Commerce & Industry, Government of India)

ENGINEERING AND PROCESSING DIVISION

केंद्रीय गुणता नियंत्रण प्रयोगशाला

CENTRAL QUALITY CONTROL LABORATORY

रबर बोर्ड पी.ओ., कोट्टयम – 686 009 Rubber Board P.O., Kottayam – 686 009
केरल, भारत Kerala, India

TEST CERTIFICATE

Mar Baselios Public School
Manganam P.O, Near Devalokam, Kottayam
686018
marbaseliospublicschool.edu.in


Certificate No : 3397/W-1/2025
Date of issue : 16.10.2025
Customer Ref. & date : 07.10.2025
Date of Sample Receipt : 29.09.2025
Date of Completion : 14.10.2025
Sample Name : WATER

RESULT OF ANALYSIS:

Sl No	Parameter	unit	Value	Permissible Limit
1	pH	6.8	6.5 – 8.5
2	Colour	colourless	Colourless
3	Turbidity	NTU	0	1
4	Odour	Odourless	Not Objectionable
5	Fluoride	mg/ litre	Trace	1.0
6	Total Dissolved Solids	mg/ litre	220	500 (maximum)
7	Total Hardness	mg/ litre	58	300 (maximum)
8	Dissolved Oxygen	mg/ litre	8.3
9	Total Iron as Fe	mg/ litre	Trace	0.30 (maximum)
10	Nitrate	mg/ litre	Trace	45 (maximum)
11	Sulphate	mg/ litre	Trace	200 (maximum)
12	Chloride	mg/ litre	34.0	250 (maximum)
13	Coliforms	Absent	Absent
14	E.Coli	Absent	Absent
15	MPN/100ml	0	Absent


Verified by



Approved by 
Authorised Signatory
Name & Designation 